

ADDENDUM NO. 1

**GROUND STORAGE TANK PROJECT
SWEETWATER, NOLAN COUNTY, TEXAS**

May 8, 2008

We call attention to the following modifications to the referenced Plans, Specifications and Contract Documents for the above referenced project. The City of Sweetwater will receive sealed Bids for the Ground Storage Tank Project until 5:00 p.m. local time on Monday, May 12, 2008, at City Hall located at 200 E. 4th Street, Sweetwater, Texas 79556. Bids will be publicly opened and read aloud at 9:00 a.m. local time on Tuesday, May 13, 2008, at the Sweetwater City Hall. We hereby modify the documents as follows.

- [1] **CORRECTION** on Drawing Sheet S1 (5 of 10): Finish Grade elevation shall be **2184.00 (min.)** at tank wall.
- [2] **ADD** the following Note on the "Radial Dome Joint Reinforcing" Detail on Drawing Sheet S2 (6 of 10):
"Joint shall be filled to full precast panel thickness with concrete or shotcrete."
- [3] **ADD** the following information to the "Geotechnical Investigation":
"Based on available data, total and differential settlement should not exceed an estimated 4" and 2" respectively."
- [4] **ADD** the following to General Note 7 on Sheet 3 (3 of 10) and Note 7 on Sheet S1 (5 of 10):
"Any and all site work required by the Tank contractor shall be completed by the High Service Pump Station contractor. It is the responsibility of the Tank contractor to provide the scope of necessary site work to the High Service Pump Station contractor prior to bidding. This work shall be included in the appropriate HSPS Bid Proposal Items A-6 or A-7."

This addendum consists of one (1) page. This addendum becomes a part of referenced plans and specifications and shall be acknowledged by the bidder and attached to the bid packet submitted.



THE SEAL APPEARING ON THIS DOCUMENT WAS AUTHORIZED BY SCOTT F. HIBBS, P.E. 63462 ON 05/06/08. ALTERATION OF A SEALED DOCUMENT WITHOUT PROPER NOTIFICATION TO THE RESPONSIBLE ENGINEER IS AN OFFENSE UNDER THE TEXAS ENGINEERING ACT.